

**MUNICIPAL CORPORATION OF DELHI**  
**PUBLIC HEALTH DEPARTMENT**  
**SHAHDARA (SOUTH) ZONE**  
419 1<sup>ST</sup> FLOOR UDYOG SADAN, PATPAR GANJ  
INDUSTRIAL AREA DELHI-110092.

No. : DHO/Shah(S)/2023/322

Date 10/5/23

**School Health Certificate**

1. Name of School	: RISHABH PUBLIC SCHOOL
2. Location of the School	: PKT-IV, MAYUR VIHAR PH-1, DELHI- 91
3. School Timing	: 08:00 AM to 01:30 PM
4. No. of Students	: 650 (Boys 400 and Girls 250)
5. No. of Doors in each room	: Provided
6. No. of Fans in each room	: Provided
7. Building Structure	: Pucca
8. Electricity	: BSES
9. Water Supply	: DJB Bill
10. No. of Toilets for Boys	: 18
11. No. of Toilets for Girls	: 11
12. No. of Staff	: 30
13. No. of Room	: 30
14. No. of WCP	: 07 Nos

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

**Principal**  
**RISHABH PUBLIC SCHOOL,**  
**PKT-IV, MAYUR VIHAR PH-1, DELHI-110091**

**Deputy Health Officer**  
**Shahdara (South) Zone**  
MUNICIPAL CORPORATION OF DELHI  
SHAHDARA (SOUTH) ZONE

STOP CORONA VIRUS- Wash Your Hand/ Wear MASK/ Maintain Social Distance



No.DJB/QCLTYR/PD/230601


DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL LABORATORY,  
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015

ACWA-TYR

Diary No...180...dt.19/6/2023



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2023.....

DATE: - 05-06-2023

Analysis report of DJB supply water samples collected from (1) Inlet (2) Outlet. M/S Rishabh Public School, Pocket-IV, Mayur Vihar, Phase-I, Delhi- 110091, for drinking purpose.

Ref. No-RPS/05/2023 dated: 29-05-2023

Date of collection: - 01-06-2023

Challan No: - 85

dated: - 29-05-2023

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
<b>A. Physical Examination</b>						
1.	Colour	...	...	-	Clear	Clear
2.	Odour	...	...	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.96	1.02
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	236	252
6.	Total Dissolved Solids	500	2000	mg/l	153	164
<b>B. Chemical Examination</b>						
7.	P <sup>h</sup> Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	72	72
9.	Total Hardness	200	600	mg/l	92	92
10.	Calcium Hardness	...	...	mg/l	66	68
11.	Magnesium Hardness	...	...	mg/l	26	24
12.	Calcium as (Ca)	75	200	mg/l	26.4	27.2
13.	Magnesium as (Mg)	30	100	mg/l	6.24	5.76
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	...	...	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	3.83	2.23
17.	Sulphate	200	400	mg/l	24.0	29.4
18.	Chloride	250	1000	mg/l	20	22
19.	Fluoride	1.0	1.5	mg/l	N.D	N.D
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.10	0.12
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D.	N.D.
22.	Residual Chlorine	0.2	1.0	mg/l	1.13	1.10
<b>C. Bacteriological Examination</b>						
23.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conforms BIS: 10500-2012 and can be Considered fit for drinking purpose.

*Moulik*  
05-06-2023  
A/CHEMIST

*Jain*  
05/06/2023  
CHEMIST

*S. 623*  
ACWA (TYR)



**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)**  
**ROOM NO. 209, VARUNALAYA PHASE-I**  
**KAROL BAGH, NEW DELHI - 110005**  
**# 23558264**

No./DJB/EE(RWH/GWC)/2018/4707

DATED: 30/8/18


To,

Principal,  
Rishabh Public School,  
Pocket-IV, Mayur Vihar,  
Phase-I, Delhi-91

**Subject: Adequacy certificate in regard to rain water harvesting system at  
Rishabh Public School, Pocket-IV, Mayur Vihar, Phase-I, Delhi-91.**

Please refer to your letter dated 08.06.2018 in which you have informed that Rain Water Harvesting has been installed at your said premises, the rain water harvesting structure was inspected by NGT Joint Inspection Team on dated 08.08.2018 and found sufficient and adequate to harvest the catchment area of your premises.

You are therefore advised to keep are RWH system neat & clean and maintain the same periodically.

  
EE (RWH/GWC)  
EE (GWC/CEL)  
DELHI JAL BOARD  
VARUNALAYA PHASE-I,  
KAROL BAGH, NEW DELHI-110005