

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2021/ 689

Dated:- 02/08/2021

FIRE SAFETY CERTIFICATE

Certified that the Rishabh Public School located at Pocket-IV, Mayur Vihar, Phase-1, Delhi-91, comprised of A block (G+02 upper floors) & B block (B+G+03 upper floors) owned/occupied by Rishabh Public School, was granted FSC by this department vide letter No. F6/DFS/MS/School/2018/NDZ/1567 dated 05/07/2018. The premises was re-inspected by the officer concerned of this department on 23/08/2021 in the presence of the Mr. Amit Bhati (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from ~~02/08/2021~~ 02/08/2021 for a period of three years, subject to conditions printed below.

Issued on02/08/2021... at New Delhi by.



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,
D-Block, Anand Vihar, Delhi-91.
2. The Principal,
Rishabh Public School, Pocket-IV, Mayur Vihar, Phase-1, Delhi-91.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".